

New York State Department of Health Lead Testing in School Drinking Water

Beacon City School District - Beacon High School

101 Matteawan Rd. Beacon, NY 12508				Testing Laboratory Pace Analytical Laboratory FKA EnviroTest Laboratories		
Facilities Superintendent Jesse Morrill morrill.j@beaconk12.org	Sampling Firm Air Guys admin@airguys.us	Sampling Technician Bailey Workman, B.S. bailey@airguys.us	EPA Certification LBP-I-1235049-1 exp. 5/18/2025	315 Fullerton Ave. Newburgh, NY 12550 845-562-0890	Sampling Date August 16, 2022	Failed Samples 2 out of 42 4%

Sample Identification	Identifying Room	Outlet Type	Pb Content	>15ppb	Notes
BH-01-PL-WF-001-P	Pool	Water Fountain	<1.0 ug/L		Previously Used - Not First Draw Sample
BH-01-GM-WFR-002-P	Outside Gym Entrance	Water Fountain Reg. Tem	<1.0 ug/L		
BH-01-GM-WFC-003-P	Outside Gym Entrance	Water Fountain Cold Tem	<1.0 ug/L		
BH-01-GLR-WFR-004-P	Girls Locker Room	Water Fountain Reg. Tem	<1.0 ug/L		
BH-01-GLR-WFC-005-P	Girls Locker Room	Water Fountain Cold Tem	<1.0 ug/L		
BH-01-TR-DW-006-P	Trainer's Office	Drinking Water/Faucet	14 ug/L		Outlet used to fill water jugs
BH-01-OK-KFB-007-P	Kitchen	Back Kitchen Faucet	100 ug/L	Yes	Sink behind eyesight from door in back of kitchen
BH-01-OK-KF1-008-P	Kitchen	Kitchen Faucet	7.8 ug/L		In order from back left entrance - down the row - left - up the row
BH-01-OK-KF2-009-P	Kitchen	Kitchen Faucet	4.5 ug/L		
BH-01-OK-KF3-010-P	Kitchen	Kitchen Faucet	18 ug/L	Yes	
BH-01-OK-KF4-011-P	Kitchen	Kitchen Faucet	6.3 ug/L		
BH-01-OK-KF5-012-P	Kitchen	Kitchen Faucet	3.4 ug/L		
BH-01-OK-KFs-013-P	Kitchen	Kitchen Steam Faucet	3.3 ug/L		Outlet administering water to "giant pot"
BH-01-OK-KFs-014-P	Kitchen	Kitchen Double Steamer F	4.4 ug/L		Outlet administering water to "double pots"
BH-01-OK-ICE-015-P	Kitchen	Ice Machine	<1.0 ug/L		
BH-01-OK-EKF1-016-P	Outside Main Kitchen	Kitchen Faucet	2.0 ug/L		
BH-01-OK-EKF2-017-P	Outside Main Kitchen	Kitchen Faucet	3.5 ug/L		
BH-01-OK-EKF3-018-P	Outside Main Kitchen	Kitchen Faucet	1.6 ug/L		
BH-01-OK-EKF4-019-P	Outside Main Kitchen	Kitchen Faucet	6.9 ug/L		
BH-01-ON-NF1-020-P	Nurse's Office	Nurse Sink RM 1	1.6 ug/L		
BH-01-ON-NF2-021-P	Nurse's Office	Nurse Sink RM 2	<1.0 ug/L		
BH-01-ON-NF3-022-P	Nurse's Office	Nurse Bathroom Sink	<1.0 ug/L		
BH-01-CR-KF-023-P	Community Room	Kitchenette Faucet	1.0 ug/L		
BH-01-GS-KF-024-P	Guidance Offices	Kitchenette Faucet	<1.0 ug/L		
BH-01-MO-KF-025-P	Main Office	Kitchenette Faucet	<1.0 ug/L		
BH-01-MO-WFR-026-P	Outside Main Office	Water Fountain Reg. Tem	<1.0 ug/L		
BH-01-MO-WFC-027-P	Outside Main Office	Water Fountain Cold Tem	<1.0 ug/L		
BH-01-MR-WF-028-P	Music Room	Water Fountain	<1.0 ug/L		Previously Used - Not First Draw Sample
BH-01-LIB-KF-029-P	Library	Kitchenette Faucet	<1.0 ug/L		
BH-01-C133-WFR-030-P	Outside RM C133	Water Fountain Reg. Tem	<1.0 ug/L		
BH-01-C133-WFC-031-P	Outside RM C133	Water Fountain Cold Tem	2.9 ug/L		
BH-01-FCc-KF-032-P	Facility Center (C)	Kitchenette Faucet	1.0 ug/L		Previously Used - Not First Draw Sample
BH-01-B113-WFR-033-P	Outside RM B113	Water Fountain Reg. Tem	<1.0 ug/L		
BH-01-B113-WFC-034-P	Outside RM B113	Water Fountain Cold Tem	<1.0 ug/L		
BH-01-FCb-KF-035-P	Facility Center (B)	Kitchenette Faucet	<1.0 ug/L		Previously Used - Not First Draw Sample
BH-01-CAF-DW-036-P	Cafeteria	Water Bottle Filler	<1.0 ug/L		
BH-02-FC-KF-001-P	Facility Center (B)	Kitchenette Faucet	<1.0 ug/L		Previously Used - Not First Draw Sample
BH-02-B217-WFR-002-P	Outside RM B217	Water Fountain Reg. Tem	<1.0 ug/L		
BH-02-B217-WFC-003-P	Outside RM B217	Water Fountain Cold Tem	<1.0 ug/L		
BH-02-FCc-KF-004-P	Facility Center (C)	Kitchenette Faucet	1.4 ug/L		
BH-02-C237-WFR-005-P	Outside RM C237	Water Fountain Reg. Tem	<1.0 ug/L		
BH-02-C237-WFC-006-P	Outside RM C237	Water Fountain Cold Tem	<1.0 ug/L		
				2/42 FAILURES	