

New York State Department of Health Lead Testing in School Drinking Water

Beacon City School District - Glenham Elementary School

20 Chase Dr. Beacon, NY 12508				Testing Laboratory Pace Analytical Laboratory FKA EnviroTest Laboratories		
Facilities Superintendent Jesse Morrill morrill.j@beaconk12.org	Sampling Firm Air Guys admin@airguys.us	Sampling Technician Bailey Workman, B.S. bailey@airguys.us	EPA Certification LBP-I-235049-1 exp. 5/18/2025	315 Fullerton Ave. Newburgh, NY 12550 845-562-0890	Sampling Date August 9, 2022	Failed Samples 8 out of 36 22%

Sample Identification	Identifying Room	Outlet Type	Pb Content	>15ppb	Notes
GE-01-0K-KFs-001-P	Kitchen	Kitchen Steam Faucet	31 ug/L	Yes	Outlet administering water to "giant pot"
GE-01-0K-KF1-002-P	Kitchen	Kitchen Faucet 1	28 ug/L	Yes	
GE-01-0K-KF2-003-P	Kitchen	Kitchen Faucet 2	5.3 ug/L		
GE-01-MPR-DW-004-P	Multi Purpose Room	Water Bottle Faucet	<1.0 ug/L		
GE-01-0N-NF1-005-P	Nurse's Office	Nurse's Sink 1	8.0 ug/L		
GE-01-0N-NF2-006-P	Nurse's Office	Nurse's Sink 2	7.5 ug/L		
GE-01-TL-KF-007-P	Teacher's Lounge	Kitchen Faucet	1.1 ug/L		
GE-01-014-CF-008-P	Room 14	Classroom Faucet	2.3 ug/L		
GE-01-011-CF-009-P	Room 11	Classroom Faucet	2.5 ug/L		
GE-01-012-CF-010-P	Room 12	Classroom Faucet	31 ug/L	Yes	
GE-01-09-CF-011-P	Room 9	Classroom Faucet	4.5 ug/L		
GE-01-010-CF-012-P	Room 10	Classroom Faucet	9.3 ug/L		
GE-01-07-CF-013-P	Room 7	Classroom Faucet	7.3 ug/L		
GE-01-08-CF-014-P	Room 8	Classroom Faucet	11 ug/L		
GE-01-020-CF-015-P	Room 20	Classroom Faucet	5.0 ug/L		
GE-01-018-CF-016-P	Room 18	Classroom Faucet	20 ug/L	Yes	
GE-01-016-CF-017-P	Room 16	Classroom Faucet	11 ug/L		
GE-01-016-DW-018-P	Room 16	Drinking Water	11 ug/L		
GE-01-OT-WF-019-P	Occupational Therapy	Water Bottle Faucet	<1.0 ug/L		
GE-01-015-CF-020-P	Room 15	Classroom Faucet	19 ug/L	Yes	
GE-01-015-DW-021-P	Room 15	Drinking Water	7.7 ug/L		
GE-01-017-CF-022-P	Room 17	Classroom Faucet	8.7 ug/L		
GE-01-017-DW-023-P	Room 17	Drinking Water	3.2 ug/L		
GE-01-019-CF-024-P	Room 19	Classroom Faucet	4.1 ug/L		
GE-01-021-CF-025-P	Room 21	Classroom Faucet	3.3 ug/L		
GE-01-104-CF-026-P	Room 104	Classroom Faucet	7.1 ug/L		
GE-01-103-CF-027-P	Room 103	Classroom Faucet	5.1 ug/L		
GE-01-102-CF-028-P	Room 102	Classroom Faucet	5.3 ug/L		
GE-01-101-CF-029-P	Room 101	Classroom Faucet	1.4 ug/L		
GE-01-06-CF-029-P	Room 6	Classroom Faucet	11 ug/L		
GE-01-05-CF-031-P	Room 5	Classroom Faucet	14 ug/L		
GE-01-04-CF-032-P	Room 4	Classroom Faucet	18 ug/L	Yes	
GE-01-003-WF-033-P	Outside Room 3	Water Bottle Faucet	<1.0 ug/L		
GE-01-03-CF-034-P	Room 3	Classroom Faucet	17 ug/L	Yes	
GE-01-02-CF-035-P	Room 2	Classroom Faucet	15 ug/L		
GE-01-01-CF-036-P	Room 1	Classroom Faucet	16 ug/L	Yes	
				8/36 FAILURES	