

New York State Department of Health Lead Testing in School Drinking Water

Beacon City School District - Forrestal Elementary School

125 Liberty St. Beacon, NY 12508				Testing Laboratory Pace Analytical Laboratoy FKA EnviroTest Laboratories			
Facilities Superintendent	Sampling Firm	Sampling Technician	EPA Certification	315 Fullerton Ave.	Sampling Date	Failed Samples	
Jesse Morrill morrill.j@beaconk12.org	Air Guys admin@airguys.us	Bailey Workman, B.S. bailey@airguys.us	LBP-I-1235049-1 exp. 5/18/2025	Newburgh, NY 12550 845-562-0890	August 3, 2022	7 out of 28	25%

Sample Identification	Identifying Room	Outlet Type	Pb Content	>15ppb	Notes
FR-LL-06A-CF-001-P	Lower Level Rm 6A	Classroom Faucet	12 ug/L		
FR-LL-05-CF-002-P	Lower Level Rm 5	Classroom Faucet	15 ug/L		
FR-LL-07-CF-003-P	Lower Level Rm 7	Classroom Faucet	56 ug/L	Yes	
FR-LL-04-CF-004-P	Lower Level Rm 4	Classroom Faucet	11 ug/L		
FR-LL-08-CF-005-P	Lower Level Rm 8	Classroom Faucet	12 ug/L		
FR-LL-03-CF-006-P	Lower Level Rm 3	Classroom Faucet	20 ug/L	Yes	
FR-LL-09-CF-007-P	Lower Level Rm 9	Classroom Faucet	2.8 ug/L		
FR-LL-02-CF-008-P	Lower Level Rm 2	Classroom Faucet	3.8 ug/L		
FR-LL-01-CF-009-P	Lower Level Rm 1	Classroom Faucet	15 ug/L		
FR-LL-0K2-CF-010-P	Lower Level Rm K2	Classroom Faucet	11 ug/L		
FR-LL-0K1-CF-011-P	Lower Level Rm K1	Classroom Faucet	19 ug/L	Yes	
FR-LL-010-CF-012-P	Lower Level Rm 10	Classroom Faucet	5.0 ug/L		
FR-LL-012-CF-013-P	Lower Level Rm 12	Classroom Faucet	28 ug/L	Yes	
FR-01-0N-NS-001-P	First Floor Nurse Office	Nurse's Sink	3.3 ug/L		
FR-01-APR-WC-002-P	First Floor Outside All Purpose Rm	Water Cooler	<1.0 ug/L		
FR-01-0K-KF-003-P	First Floor Kitchen	Kitchen Faucet	9.1 ug/L		
FR-01-0K-KFs-004-P	First Floor Kitchen	Kitchen Steam Faucet	12 ug/L		Outlet administering water to "giant pot"
FR-01-TL-KF-005-P	First Floor Teacher's Lounge	Kitchen Sink Faucet	5.7 ug/L		
FR-01-016-CF-006-P	First Floor Rm 16	Classroom Faucet	17 ug/L	Yes	
FR-01-016-CFs-007-P	First Floor Rm 16	Classroom Faucet	2.4 ug/L		
FR-01-017-CF-008-P	First Floor Rm 17	Classroom Faucet	22 ug/L	Yes	Faucet found dripping during walkthrough
FR-01-018-CF-009-P	First Floor Rm 18	Classroom Faucet	22 ug/L	Yes	
FR-01-019-CF-010-P	First Floor Rm 19	Classroom Faucet	11 ug/L		
FR-01-020-CF-011-P	First Floor Rm 20	Classroom Faucet	11 ug/L		
FR-LL-05-WFR-001-P	Lower Level Outside Rm 5	Water Fountain Reg. Temp	1.8 ug/L		
FR-LL-05-WFC-002-P	Lower Level Outside Rm 5	Water Fountain Cold Temp	<1.0 ug/L		
FR-01-CUS-WFR-003-P	First Floor Outside Kitchen/APR	Water Fountain Reg. Temp	<1.0 ug/L		
FR-01-CUS-WFC-004-P	First Floor Outside Kitchen/APR	Water Fountain Cold Temp	<1.0 ug/L		
				7/28 FAILURES	