

New York State Department of Health Lead Testing in School Drinking Water

Beacon City School District - Rombout Middle School

84 Matteawan Rd.
Beacon, NY 12508

Testing Laboratory
Pace Analytical Laboratory
FKA EnviroTest Laboratories

Facilities Superintendent

Jesse Morrill
morrill.j@beaconk12.org

Sampling Firm

Air Guys
admin@airguys.us

Sampling Technician

Bailey Workman, B.S.
bailey@airguys.us

EPA Certification

LBP-I-1235049-1
exp. 5/18/2025

315 Fullerton Ave.
Newburgh, NY 12550
845-562-0890

Sampling Date

August 24, 2022

Failed Samples

9 out of 37 24%

| Sample Identification | Identifying Room | Outlet Type | Pb Content | >15ppb | Notes |
|-----------------------|------------------------------------|--------------------------|------------|--------|--|
| RM-01-SD-KF-001-P | Staff Room | Kitchenette Faucet | 2.5 ug/L | | |
| RM-01-0K-KF1-002-P | Kitchen | Kitchen Faucet | 1.0 ug/L | | |
| RM-01-0K-KFw-003-P | Kitchen | Kitchen Wide Pan Faucet | 55 ug/L | Yes | Possibly administering water to wide pans underneath, not DW? discol |
| RM-01-0K-KFs-004-P | Kitchen | Kitchen Steam Faucet | 1.3 ug/L | | Outlet administering water to "giant pot" |
| RM-01-0K-KF2-005-P | Kitchen | Kitchen Faucet | 2.4 ug/L | | |
| RM-01-0K-ICE-006-P | Kitchen | Ice Machine | <1.0 ug/L | | |
| RM-01-CUS-WFR-007-P | Outside Custodial Office | Water Fountain Reg. Temp | <1.0 ug/L | | Across the hallway against a wall facing the exit doors |
| RM-01-CUS-WFC-008-P | Outside Custodial Office | Water Fountain Cold Temp | <1.0 ug/L | | |
| RM-01-C129-CF-009-P | First Floor Rm C129 | Classroom Faucet | 13 ug/L | | |
| RM-01-0N-NF-010-P | Nurse's Office | Nurse's Sink | 6.4 ug/L | | |
| RM-01-D134-WF-011-P | First Floor Rm D134 | Drinking Water | <1.0 ug/L | | |
| RM-01-D134-CF-012-P | First Floor Rm D134 | Classroom Faucet | 15 ug/L | | |
| RM-01-D136-CF-013-P | First Floor Rm D136 | Classroom Faucet | 7.8 ug/L | | |
| RM-01-D137-CF-014-P | First Floor Rm D137 | Classroom Faucet | 110 ug/L | Yes | |
| RM-01-D138-CF-015-P | First Floor Rm D138 | Classroom Faucet | 43 ug/L | Yes | |
| RM-01-D139-CF-016-P | First Floor Rm D139 | Classroom Faucet | 38 ug/L | Yes | |
| RM-01-D140-CF-017-P | First Floor Rm D140 | Classroom Faucet | 13 ug/L | | |
| RM-01-B118-CF-018-P | First Floor Rm B118 | Classroom Faucet | 16 ug/L | Yes | |
| RM-01-B116-CF-019-P | First Floor Rm B116 | Classroom Faucet | 2.4 ug/L | | |
| RM-01-A1091-CF-020-P | First Floor Rm A109 - Home Ec | Classroom Faucet | 3.1 ug/L | | Begins HomeEc room, from Left to Right Starting with the Back Table |
| RM-01-A1092-CF-021-P | First Floor Rm A109 - Home Ec | Classroom Faucet | 2.0 ug/L | | " |
| RM-01-A1093-CF-022-P | First Floor Rm A109 - Home Ec | Classroom Faucet | 1.2 ug/L | | " |
| RM-01-A1094-CF-023-P | First Floor Rm A109 - Home Ec | Classroom Faucet | 1.9 ug/L | | " |
| RM-01-A1095-CF-024-P | First Floor Rm A109 - Home Ec | Classroom Faucet | 1.7 ug/L | | " |
| RM-01-A1096-CF-025-P | First Floor Rm A109 - Home Ec | Classroom Faucet | 1.6 ug/L | | " |
| RM-01-AP-WFR-026-P | Outside Assistant Principal Office | Water Fountain Reg. Temp | <1.0 ug/L | | |
| RM-01-AP-WFC-027-P | Outside Assistant Principal Office | Water Fountain Cold Temp | <1.0 ug/L | | |
| RM-02-H"B"-WFR-001-P | Second Floor Hallway "B" | Water Fountain Reg. Temp | <1.0 ug/L | | Water F in Hallway where classrooms have "B" labeled |
| RM-02-H"B"-WFC-002-P | Second Floor Hallway "B" | Water Fountain Cold Temp | <1.0 ug/L | | |
| RM-02-D234-WFR-003-P | Second Floor Outside Rm D234 | Water Fountain Reg. Temp | <1.0 ug/L | | Water F in Hallway where classrooms have "D" labeled |
| RM-02-D234-WFC-004-P | Second Floor Outside Rm D234 | Water Fountain Cold Temp | <1.0 ug/L | | |
| RM-02-D234-CF-005-P | Second Floor Rm D234 | Classroom Faucet | 17 ug/L | Yes | |
| RM-02-D235-CF-006-P | Second Floor Rm D235 | Classroom Faucet | 6.7 ug/L | | |
| RM-02-D236-CF-007-P | Second Floor Rm D236 | Classroom Faucet | 4.6 ug/L | | |
| RM-02-D238-CF-008-P | Second Floor Rm D238 | Classroom Faucet | 17 ug/L | Yes | |
| RM-02-D239-CF-009-P | Second Floor Rm D239 | Classroom Faucet | 32 ug/L | Yes | |
| RM-02-D240-CF-010-P | Second Floor Rm D240 | Classroom Faucet | 41 ug/L | Yes | |

9/37 FAILURES