

New York State Department of Health Lead Testing in School Drinking Water

Beacon City School District - Sargent Elementary School

29 Education Dr. Beacon, NY 12508				Testing Laboratory Pace Analytical Laboratory FKA EnviroTest Laboratories		
Facilities Superintendent Jesse Morrill morrill.j@beaconk12.org	Sampling Firm Air Guys admin@airguys.us	Sampling Technician Bailey Workman, B.S. bailey@airguys.us	EPA Certification LBP-I-1235049-1 exp. 5/18/2025	315 Fullerton Ave. Newburgh, NY 12550 845-562-0890	Sampling Date August 9, 2022	Failed Samples 10 out of 32 31%

Sample Identification	Identifying Room	Outlet Type	Pb Content	>15ppb	Notes
SE-LL-0K-KF1-001-P	Kitchen	Kitchen Faucet	18 ug/L	Yes	Outlet administering water to "giant pot"
SE-LL-0K-KFs-002-P	Kitchen	Kitchen Steam Faucet	17 ug/L	Yes	
SE-LL-0K-KF2-003-P	Kitchen	Kitchen Faucet	38 ug/L	Yes	Previously Used - Not First Draw Sample
SE-LL-TL-KF-004-P	Teacher's Lounge	Kitchen Faucet	5.9 ug/L		
SE-LL-0TL-WF-005-P	Outside Teacher's Lounge	Water Bottle Faucet	<1.0 ug/L		
SE-01-05-CF-006-P	Room 5	Classroom Faucet	3.2 ug/L		
SE-01-06-CF-007-P	Room 6	Classroom Faucet	10 ug/L		
SE-01-07-CF-008-P	Room 7	Classroom Faucet	8.0 ug/L		
SE-01-08-CF-009-P	Room 8	Classroom Faucet	7.9 ug/L		
SE-01-PSY-CF-010-P	Psychologist Office	Classroom Faucet	6.4 ug/L		
SE-01-010-CF-011-P	Room 10	Classroom Faucet	30 ug/L	Yes	
SE-01-011-CF-012-P	Room 11	Classroom Faucet	6.0 ug/L		
SE-01-012-CF-013-P	Room 12	Classroom Faucet	9.8 ug/L		
SE-01-013-WF-014-P	Outside Room 13	Water Bottle Faucet	<1.0 ug/L		
SE-01-013-CF-015-P	Room 13	Classroom Faucet	32 ug/L	Yes	
SE-01-013-DW-016-P	Room 13	Drinking Water	8.7 ug/L		
SE-01-022-CF-017-P	Room 22	Classroom Faucet	6.5 ug/L		
SE-01-024-CF-018-P	Room 24	Classroom Faucet	3.6 ug/L		
SE-01-025-CF-019-P	Room 25	Classroom Faucet	2.7 ug/L		
SE-01-026-CF-020-P	Room 26	Classroom Faucet	2.6 ug/L		
SE-01-027-CF-021-P	Room 27	Classroom Faucet	3.6 ug/L		
SE-01-028-CF-022-P	Room 28	Classroom Faucet	3.4 ug/L		
SE-01-030-CF-023-P	Room 30	Classroom Faucet	42 ug/L	Yes	
SE-01-029-CF-024-P	Room 29	Classroom Faucet	4.6 ug/L		
SE-02-014-BF-001-P	Room 14	Bathroom Faucet	46 ug/L		
SE-02-015-CF-002-P	Room 15	Classroom Faucet	50 ug/L	Yes	
SE-02-016-CF-003-P	Room 16	Classroom Faucet	23 ug/L	Yes	
SE-02-017-CF-004-P	Room 17	Classroom Faucet	3.6 ug/L		
SE-02-018-CF-005-P	Room 18	Classroom Faucet	7.5 ug/L		
SE-02-019-CF-006-P	Room 19	Classroom Faucet	5.7 ug/L		
SE-02-020-CF-007-P	Room 20	Classroom Faucet	18 ug/L	Yes	
SE-02-021-CF-008-P	Room 21	Classroom Faucet	8.4 ug/L		
				10/32 FAILURES	