

New York State Department of Health Lead Testing in School Drinking Water

Beacon City School District - South Avenue Elementary School

60 South Ave. Beacon, NY 12508				Testing Laboratory Pace Analytical Laboratory FKA EnviroTest Laboratories			
Facilities Superintendent Jesse Morrill morrill.j@beaconk12.org	Sampling Firm Air Guys admin@airguys.us	Sampling Technician Bailey Workman, B.S. bailey@airguys.us	EPA Certification LBP-I-1235049-1 exp. 5/18/2025	315 Fullerton Ave. Newburgh, NY 12550 845-562-0890	Sampling Date August 3, 2022	Failed Samples 0 out of 21 0%	

Sample Identification	Identifying Room	Outlet Type	Pb Content	>15ppb	Notes
SA-LL-TL-KF-001-P	Lower Level Teachers Lounge	Kitchen Sink Faucet	<1.0 ug/L		
SA-01-0N-NS-001-P	First Floor Nurse	Nurse's Sink	2.1 ug/L		
SA-01-06-CF-002-P	First Floor Rm 6	Classroom Faucet	4.4 ug/L		Faucet found leaking/dripping during walkthrough
SA-01-04-CF-003-P	First Floor Rm 4	Classroom Faucet	8.3 ug/L		
SA-01-023-CF-004-P	First Floor Rm 23	Classroom Faucet	1.5 ug/L		
SA-01-023-DW-005-P	First Floor Rm 23	Drinking Water	4.6 ug/L		Faucet found leaking/dripping during walkthrough
SA-01-022-CF-006-P	First Floor Rm 22	Classroom Faucet	3.9 ug/L		
SA-01-022-DW-007-P	First Floor Rm 22	Drinking Water	11 ug/L		
SA-01-021-CF-008-P	First Floor Rm 21	Classroom Faucet	5.3 ug/L		
SA-01-0K-DW-009-P	First Floor Kitchen	Drinking Water	<1.0 ug/L		
SA-01-0K-KF1-010-P	First Floor Kitchen	Kitchen Faucet 1	1.0 ug/L		
SA-01-0K-KF2-011-P	First Floor Kitchen	Kitchen Faucet 2	9.1 ug/L		
SA-01-0K-KFs-012-P	First Floor Kitchen	Kitchen Steam Faucet	6.1 ug/L		Outlet administering water to "giant pot"
SA-01-PE-WFR-001-P	First Floor Outside Gym	Water Fountain Reg. Temp	<1.0 ug/L		On right side of the gym doors
SA-01-PE-WFC-002-P	First Floor Outside Gym	Water Fountain Cold Temp	<1.0 ug/L		
SA-01-0N-WFR-003-P	First Floor Outside Nurse	Water Fountain Reg. Temp	<1.0 ug/L		On the left side of the gym doors in front of the nurse's office
SA-01-0N-WFC-004-P	First Floor Outside Nurse	Water Fountain Cold Temp	<1.0 ug/L		
SA-02-07-WFR-005-P	Second Floor Outside Rm 7	Water Fountain Reg. Temp	<1.0 ug/L		
SA-02-07-WFC-006-P	Second Floor Outside Rm 7	Water Fountain Cold Temp	<1.0 ug/L		
SA-02-019-WFR-007-P	Second Floor Outside Rm 19	Water Fountain Reg. Temp	<1.0 ug/L		
SA-02-019-WFC-008-P	Second Floor Outside Rm 19	Water Fountain Cold Temp	3.4 ug/L		
NO FAILURES					